



DDZR.MH26624 Liners

[Page Bottom](#)

Liners

[See General Information for Liners](#)

NORTH AMERICAN SUPAFU SYSTEMS INC

MH26624

UNIT 203
15 HOLLY ST
PO BOX 2350
SCARBOROUGH, ME 04070 USA

Supafu Type "HT", Cementitious Chimney Lining System. In sizes 4 thru 16 in. I.D. For use as an alternate lining system for fire-clay flue linings in masonry chimneys intended for use with gas, liquid and solid fuel-fired residential and building heating appliances intended for use with Type B vents. Clearance between combustible construction and outer chimney surfaces is zero (0) in. Minimum chimney liner thickness from I.D. of chimney liner to masonry chimney is 5/8 in. For maximum chimney height of 80 ft.

[Last Updated on 2000-04-27](#)

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2009 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2009 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.





DDZR.GuidelInfo Liners

[View Listings](#)

[Page Bottom](#)

[Chimneys, Fireplaces, Vents and Solid-fuel-burning Appliances] (Chimneys) Liners

[See General Information for Chimneys, Fireplaces, Vents and Solid-fuel-burning Appliances](#)

The chimney liners covered in this category are intended for installation, (1) as alternate lining systems for fire clay flue linings (as described in ASTM C315) or (2) in the fire clay flue linings in masonry chimneys constructed in accordance with the Standard of the National Fire Protection Association for Chimneys, Fireplaces, Vents and Solid Fuel-Burning Appliances, NFPA 211, or applicable model building code requirements.

Separate chimney liner parts required for installation of chimney liners are specified in the installation instructions provided with the chimney liners. Unless specified in the individual Listings, these chimney liners are intended for use with gas, liquid and solid-fuel-fired, residential-type and building-heating appliances specified in the Chimney Selection Chart of the National Fire Protection Association Standard NFPA 211.

The basic standard used to investigate products in this category is [UL 177Z](#), "Chimney Liners" .

The Listing Mark of Underwriters Laboratories Inc. on the product is the only method provided by Underwriters Laboratories Inc. to identify products produced under its Listing and Follow-Up Service.

The Listing Mark on these products includes the name and/or symbol of Underwriters Laboratories Inc. (as illustrated in the Introduction of this Directory) together with the word "LISTED" , a control number, and one of the following product names as appropriate: (A) "Chimney Liner," (B) "Chimney Liner Part Intended For Use With (Company Name) Listed Chimney Liner Parts" , (C) "Chimney Liner Material Intended For Use With (Company Name) Listed Chimney Liner Parts" , or (D) "Chimney Liner Part." Each Listed Chimney Liner section bears a Listing Mark with a product name similar to (A); when a combination of proprietary parts or materials are required to complete the chimney liner installation, the part or material bears a Listing Mark similar to (B) or (C); and each additional part bears a Listing Mark with a product name similar to (D).

[Last Updated on 1988-08-11](#)

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2009 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2009 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

